



FAYETTE WATER SUPPLY CORPORATION

200 Bordovsky Rd, P.O. Box 724
La Grange, TX 78945
979-968-6475
Fax: 979-968-8239
www.fayettewsc.com

Consumer Confidence Report 2024

Annual Drinking Water Quality Report for January 1, 2024 to December 31, 2024

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (979) 968-6475.

Public Participation Opportunities: Members are welcome to attend the monthly Board Meetings held every third Monday of the month at 4:30PM. Please contact the FWSC office for details.

Definitions and Abbreviations

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALC): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MFL: million fibers per liter (a measure of asbestos)

Mrem: millirems per year (a measure of radiation absorbed by the body)

Na: not applicable.

NTU: nephelometric turbidity units (a measure of turbidity)

pCi/L: picocuries per liter (a measure of radioactivity)

ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

ppq: parts per quadrillion, or picograms per liter (pg/L)

ppt: parts per trillion, or nanograms per liter (ng/L)

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

Information About Your Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the FWSC office at (979) 968-6475.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

FWSC West: Public Water System (PWS) ID TX 0750022

Information About Source Water

TCEQ completed an assessment of your source water, and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system contact the FWSC Office (979) 968-6475.

Source Water Name	Type of Water	Report Status	Location
3 – West Point	GW	Y	Aquifer: Queen City
4 – Swiss Alp	GW	Y	Aquifer: Jasper
8 - FM 1115	GW	Y	Aquifer: Queen City
7 - Roy Rd/Brewer	GW	Y	Aquifer: Carrizo
10 – Barnes/Hwy 71	GW	Y	Aquifer: Carrizo

Lead and Copper

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2024	1.3	1.3	0.146	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	2024	0	15	3.15	0	Ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

2024 Water Quality Test Results

Disinfection By-Products	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)	2024	14	0 – 20.6	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
* The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year*								
Total Trihalomethanes (TTHM)	2024	57	7.9 – 99.3	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
* The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year*								
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta/photon emitters	2023	4.5	0 – 4.5	0	50	pCi/L	N	Decay of natural and man-made deposits
*EPA considers 50 pCi/L to be the level of concern for beta particles.								
Combined Radium 226/228	2021	1.5	1.5 – 1.5	0	5	pCi/L	N	Erosion of natural deposits.

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic	2024	8	0 – 8.4	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
*While your drinking water meets EPA standards for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.								
Barium	2023	0.118	0.0113 – 0.118	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2023	0.35	0 – 0.35	4	4	Ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer & aluminum factories
Chromium	2022	10.8	0 – 10.8	100	100	ppm	N	Discharge from steel and pulp mills; Erosion of natural deposits.
Nitrate [measured as Nitrogen]	2024	0.13	0 – 0.13	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Selenium	2023	10.8	0 – 10.8	50	50	ppb	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines

Disinfectant Residual	Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Unit of Measure	Violation	Source in Drinking Water
Chlorine (Free)	2024	1.27	0.23 – 2.26	4	4	ppm	N	Water additive used to control microbes.

Parameter	Detected Average	Detected Range	UCMR MRL	MCLG	MCL	Violation
Lithium	40.0 µg/L	22.4 to 58.8 µg/L	9 µg/L	N/A	N/A	No

Lithium was detected during the April and October 2023 sampling events, with results ranging from 22.4 to 58.8 µg/L. There is no EPA Maximum Contaminant Level (MCL) established for lithium.

For more information on lithium, please see the following resources at: <https://www.epa.gov/dwucmr/fifth-unregulated-contaminant-monitoring-rule#lithium>.

All UCMR5 results are available in the FWSC Office. To request a copy, please come by our office or email us at info@fayettewsc.com.

A service line inventory has been prepared and there is no lead, galvanized requiring replacement, or unknown service lines within our system. To view the lead service line inventory, please contact our office at 979-968-6475 or email us at info@fayettewsc.com.

Fayette Water Supply Corporation has emergency interconnect agreements with the following systems. The interconnect with Fayette County WCID was used in 2023. The water source for The City of La Grange and the Fayette County Water Control and Improvement District – Monument Hill is ground water. For further information regarding water quality, please feel free to contact them for their Consumer Confidence report.

- City of La Grange (PWS ID TX0750003), 155 E Colorado St., La Grange TX 78945 (979) 968-3127 or visit them online: <http://www.cityoflg.com/departments/utilities.php>
- Fayette County Water Control and Improvement District (FCWCID) – Monument Hill (PWS ID TX0750009), 100 Country Club Dr, La Grange TX 78945 (979) 968-5514 or visit them online: <http://monumenthillwater.com/home/>

FWSC East: Public Water System (PWS) ID TX 0750034

Information About Source Water

TCEQ completed an assessment of your source water, and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system contact the FWSC Office (979) 968-6475.

Source Water Name	Type of Water	Report Status	Location
5 - Walhalla	GW	Y	Aquifer: Jasper
6 – Ruttersville	GW	Y	Aquifer: Yegua Jackson

Lead and Copper

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2024	1.3	1.3	0.25	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	2024	0	15	0.42	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

2024 Water Quality Test Results

Disinfection By-Products	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)	2024	2	2.3 – 2.3	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
** The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year'								
Total Trihalomethanes (TTHM)	2024	16	15.5 – 15.5	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
** The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year'								

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2024	0.071	0.0653 – 0.071	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2024	0.26	0.21 – 0.26	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta/photon emitters	2024	16.5	10.1 – 16.5	0	50	pCi/L*	N	Decay of natural and man-made deposits.
*EPA considers 50 pCi/L to be the level of concern for beta particles.								
Combined Radium 226/228	2024	1.2	1.2 – 1.2	0	5	pCi/L	N	Erosion of natural deposits
Gross alpha excluding radon and uranium	2024	8.6	0 – 8.6	0	15	pCi/L	N	Erosion of natural deposits

Disinfectant Residual	Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Unit of Measure	Violation	Source in Drinking Water
Chlorine (Free)	2024	1.31	0.27 – 4.0	4	4	ppm	N	Water additive used to control microbes.

A service line inventory has been prepared and there is no lead, galvanized requiring replacement, or unknown service lines within our system. To view the lead service line inventory, please contact our office at 979-968-6475 or email us at info@fayettewsc.com.

Fayette Water Supply Corporation has an emergency interconnect agreement with The City of La Grange that was not used by FWSC during 2023. For further information regarding their water quality, please feel free to contact them for their Consumer Confidence report.

City of La Grange (PWS ID TX0750003), 155 E Colorado St., La Grange TX 78945 (979) 968-3127 or visit them online: <http://www.cityoflg.com/departments/utilities.php>